



ATTUNED POLYMERS LABORATORIES

Corrs. Add.: 308-313, Rajasthan Technical Centre, Patanwala Estate, L. B. S. Marg, Ghatkopar (W),
Mumbai-400 086. INDIA.. ☎ : 0091-22-2500 1556 / 3282 / 4513 Fax : 0091-22-2500 3282
E-Mail : attuned11@yahoo.com / attuned03@yahoo.com

Report No. : 1626 / 2016-2017	Date : 28.02.2017
Customer Name & Address : Polygamma Industries Private Limited A-229, Antop Hill Warehousing Complex, Vidyalankar College Road, Wadala (E), Mumbai-400037	Letter Ref. No. : Nil
Page No. : 1/1	Date of Receipt : 28.02.2017 Date of Completion : 28.02.2017

TEST REPORT

Sample Ref :	EPDM Membrane With Bonding Adhesive Overlap
Test :	Test Results
i. Average Adhesion Strength (kPa) (ASTM D 816 - 06 Method B)	116.53
Note :	Sample Does Not Break In The Joint But Breaks In The Sheet.
V 	
NAME : GOPALRAO B. DESALE	DESIGNATION : LAB INCHARGE

The information given in this report is based on the sample/s given by the customer and is true to best of our knowledge. We are not liable for any legal action taken based on this report. Test report shall not be reproduced except in full, without written approval of the laboratory.

- Sample not drawn by us.
- Results relate only to the items tested.
- Only typed matter should be considered as part of the report.

